



THE CITY OF ASPEN



## MEMORANDUM OF POLICY

### Building Codes

FROM: Tom Parry

DATE: January 28, 1998

APPROVED: Russell A. Grance, C.B.O.  
Deputy Chief Building Official

DATE: April 12, 2003

SUBJECT: **Makeup-Air for Residential Kitchen Hoods**

---

Residential kitchen exhaust hoods rated greater than 1000 cfm shall supply makeup air equal to the exhaust amount of cfm that exceed 1000 and be connected with an interlocking electric switch.